



### System No. C-AJ-2112


December 20, 2000

F Rating — 3 Hr

T Ratings — 1 and 1-1/2 Hr (See Item 2)

L Rating At Ambient — 28 CFM/sq ft

L Rating At 400 F — Less Than 1 CFM/sq ft



1. **Floor or Wall Assembly** — Min 4-1/2 in. thick reinforced lightweight or normal weight (100-150 pcf) concrete. Wall may also be constructed of any UL Classified **Concrete Blocks\***. Max diam of opening is 4 in.

See **Concrete Blocks** (CAZT) category in the Fire Resistance Directory for names of manufacturers.

2. **Through Penetrants** — One nonmetallic pipe to be centered within the firestop system. Pipe to be rigidly supported on both sides of floor or wall assembly. The following types and sizes of nonmetallic pipes may be used:

A. **Polyvinyl Chloride (PVC) Pipe** — Nom 2 in. diam (or smaller) Schedule 40 solid-core PVC pipe for use in closed (process or supply) piping system. A nom annular space of 7/8 in. is required within the firestop system. When PVC pipe is used, the T Rating is 1-1/2 h.

B. **Chlorinated Polyvinyl Chloride (CPVC) Pipe** — Nom 2 in. diam (or smaller) SDR 17 CPVC pipe for use in closed (process or supply) piping systems. A nom annular space of 7/8 in. is required within the firestop system. When CPVC pipe is used, the T Rating is 1-1/2 h.

C. **Polybutylene (PB) Pipe** — Nom 2 in. diam (or smaller) SDR11 PB pipe for use in closed (process or supply) piping systems. A nom annular space of 1 in. is required within the firestop

system. When PB pipe is used, the T Rating is 1 h.

3. **Firestop System** — The firestop system shall consist of the following:

A. **Packing Material** — (Optional) — Foam backer rod firmly packed into opening as a permanent form. Packing material to be recessed from top surface of floor or from both surfaces of wall as required to accommodate the required thickness of fill material.

B. **Fill, Void or Cavity Material\*** — Sealant — Min 1 in. thickness of fill material applied within the annulus, flush with top surface of floor or with both surfaces of wall.

**RECTORSEAL** — Metacaulk 1000

\*Bearing the UL Classification Mark