




### System No. C-AJ-2687

May 19, 2014

ANSI/UL1479 (ASTM E814)	CAN/ULC S115
F Rating — 3 Hr	F Rating — 3 Hr
T Rating — 3 Hr	FT Rating — 3 Hr
	FH Rating — 3 Hr
	FTH Rating — 3 Hr



System tested with a pressure differential of 50 Pa between the exposed and the unexposed surfaces with the higher pressure on the exposed side.

**1. Floor or Wall Assembly** — Min 114 mm (4-1/2 in.) thick lightweight or normal weight (100-150 pcf or 1600-2400 kg/m<sup>3</sup>) concrete. Wall may also be constructed of any UL Classified **Concrete Blocks\***. Floor may also be constructed of any min 6 in. (152 mm) thick UL Classified hollow-core **Precast Concrete Units\***. Max diam of opening 7 in. (178 mm).

See **Concrete Blocks** (CAZT) and Precast Concrete Units\* (CFTB) categories in the Fire Resistance Directory for names of manufacturers.

**2. Through Penetrants** — One nonmetallic pipe to be installed eccentrically or concentrically within the firestop system. Pipe to be rigidly supported on both sides of wall assembly. The following types and sizes of nonmetallic pipes may be used:

**A. Polyvinyl Chloride (PVC) Pipe** — Nom 6 in. (152 mm) diam (or smaller) Schedule 40 cellular or solid core PVC pipe for use in vented (drain, waste or vent) piping systems.

**3. Firestop System** — The firestop system shall consist of the following:

**A. Fill, Void or Cavity Material\* — Wrap Strip** — Nom 1/4 in. (6 mm) thick by 2 in. (51 mm) wide intumescent wrap strip individually wrapped around the outer circumference of the pipe

with ends butted and held in place with masking tape. Butted ends in successive layers shall be offset. Wrap strip tightly against the bottom surface of floor or both surfaces of wall. The pipe size, annular space and number of wrap strip layers are shown in the table below:

Nom Pipe Diam, In. (mm)	Annular Space, mm (In.)	No. of Wrap Strip Layers
6 (152) or smaller	0-3/8 (0 to 8)	3
4 (102) or smaller	0-1/2 (0 to 13)	2

**RECTORSEAL** — Metacaulk Wrap Strip

**B. Steel Collar** — Collar fabricated from coils of precut min 0.016 in. (0.41 mm) thick (No. 28 gauge) galv steel available from fill material manufacturer. Collar shall be nom 2 in. (51 mm) deep with 1 in. (25 mm) wide by 1-1/4 in. (32 mm) long anchor tabs on 4 in. (102 mm) centers for securement to the underside of floor or both surfaces of wall. In addition, collar contains retainer tabs 1/2 in. (13 mm) wide by 3/4 in. (19 mm) long, located opposite the anchor tabs. Collar shall be wrapped over the wrap strip, with ends overlapping min 1 in. (25 mm). For 6 in. (152 mm) diam pipes two revolutions of steel collar or 1 revolution of steel collar with a nominal 1/2 in. (13 mm) wide by 0.028 in. (0.71 mm) thick stainless steel hose clamp at mid-height is required. The retainer tabs are folded 90 deg towards the pipe to maintain the annular space around the pipe and to retain the wrap strip. Collar secured to bottom surface of the floor or both surfaces of wall at each anchor tab by means of min 1/4 in. (6 mm) diam by 1-1/4 in. (31 mm) long steel expansion bolts or steel Tapcon® concrete anchors in conjunction with 1/4 in. (6 mm) by 5/8 in. (16 mm) diam washers.

**C. Fill, Void or Cavity Material\* — Caulk** — (Not Shown) - When hollow-core floors are used, a min 6 mm (1/4 in.) thickness of caulk shall be applied within the annulus, flush with the top surface of floor.

**RECTORSEAL** — Metacaulk 1000 or Metacaulk 350i

\* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.