



System No. C-AJ-6031


September 25, 2001

F Rating — 2 Hr

T Rating — 0 Hr

Leakage Rating At Ambient — Less Than 1 CFM/Sq. Ft

Leakage Rating At 400 F — 3 CFM/Sq. Ft



1. **Floor or Wall Assembly** — Min 4-1/2 in. thick reinforced lightweight or normal weight (100-150 pcf) concrete floor or min 5 in. thick reinforced lightweight or normal concrete wall. Wall may also be constructed of any UL Classified **Concrete Blocks***. Max area of opening is 360 sq. in. with max dimension of 30 in.

See **Concrete Blocks** (CAZT) in the Fire Resistance Directory for names of manufacturers.

2. **Busway+** — Nom 27 in. wide by 6 in. deep (or smaller) "I" shaped aluminum and steel enclosure containing factory mounted copper or aluminum bars rated for 600 V, 4000A. One busway to be installed within the opening. The annular space between the busway and the periphery of the opening shall be min 3/4 in. to max 4 in. Busway to be rigidly supported on both sides of floor and wall assembly. The busway shall bear the UL Listing Mark and shall be installed in accordance with all provisions of Article 364 of the National Electrical Code, NFPA 70.

3. **Firestop System** — The firestop system shall consist of the following:

A. **Packing Material** — Min 4 in. thickness of min 4 pcf mineral wool batt insulation packed at 50 percent compression into opening as a permanent form. Packing material to be recessed from both surfaces of wall as required to accommodate the required thickness of fill material.

B. **Fill, Void or Cavity Material* - Caulk** — Min 3/8 in. thickness of fill material applied within the annulus, flush with top surface of floor and both surfaces of wall.

RECTORSEAL — Metacaulk 835+

+Bearing the UL Listing Mark

*Bearing the UL Classification Mark