




## System No. C-AJ-8138

December 03, 2003

**F Rating — 2 Hr**

**T Rating — 0 Hr**



1. **Floor or Wall Assembly** — Min 4-1/2 in. thick reinforced lightweight or normal weight (100-150 pcf) concrete floor. Wall may also be constructed of any UL classified **Concrete Blocks\***. Max area of opening is 240 sq in. with max dimension of 30 in.

See **Concrete Blocks** (CAZT) category in the Fire Resistance Directory for names of manufacturers.

2. **Through-Penetrants** — Max eight pipes, conduits or tubing to be installed within the opening. The space between pipes, conduits or tubing shall be a min 1/2 in. to max 2-3/4 in. The space between pipes, conduits or tubing and periphery of opening shall be min 0 in. (point contact) to max 3-1/4 in. Pipe, conduit or tubing to be rigidly supported on both sides of floor or wall assembly. The following types and sizes of pipes, conduits or tubing may be used:

- A. **Steel Pipe** — Nom 6 in. diam (or smaller) Schedule 10 (or heavier) steel pipe.
- B. **Copper Pipe** — Nom 3 in. diam (or smaller) regular (or heavier) copper pipe.
- C. **Copper Tubing** — Nom 3 in. diam (or smaller) Type L (or heavier) copper tubing.
- D. **Conduit** — Nom 4 in. diam (or smaller) steel electrical metallic tubing or rigid steel conduit.
- E. **Flexible Metal Gas Pipe** — Nom. 2 in. diam (or smaller) with PVC jacket

### **GASTITE, DIV OF TITEFLEX**

3. **Firestop System** — The firestop system shall consist of the following:

A. **Packing Material** — Min 3 in. thickness of min 4 pcf mineral wool batt insulation firmly packed into opening as a permanent form. Packing material to be recessed from top surface of floor or both surfaces of wall to accommodate the required thickness of fill material.

B. **Fill, Void or Cavity Material\* - Caulk** — Min 1/2 in. thickness of fill material applied within the annulus, flush with top surface of floor and both surfaces of wall. When min 4 in. of min 4 pcf mineral wool batt insulation is used as described above, thickness of fill material may be reduced to 1/4 in. A min 1/4 in. diam bead of caulk shall be applied to the penetrant/opening interface at the point contact location on the top surface of floor or both surfaces of wall.

\*Bearing the UL Classification Mark