


### System No. W-J-2063

December 03, 1999

F Rating — 2 Hr

T Ratings — 1-3/4 and 2 Hr (See Item 2)



1. **Wall Assembly** — Min 6 in. thick reinforced lightweight or normal weight (100-150 pcf) concrete. Wall may also be constructed of any UL Classified **Concrete Blocks\***. Max diam of opening is 4 in. **The T Rating of the firestop system is 1-3/4 hr when the diam of the opening is greater than 2-1/16 in. larger than the outside diam of the penetrant and 2 hr when the diam of the opening is less than or equal to 2-1/16 in. larger than the outside diam of the penetrant.**

See **Concrete Blocks** (CAZT) category in the Fire Resistance Directory for names of manufacturers.

2. **Nonmetallic Penetrant** — One nonmetallic penetrant to be installed either concentrically or eccentrically within the firestop system. The annular space between nonmetallic penetrant and periphery of opening shall be min 0 in. (point contact) to max 2-1/16 in. Through-penetrant shall be rigidly supported on both sides of wall assembly. The following types and sizes of nonmetallic penetrants may be used:

A. **Electrical Nonmetallic Tubing (ENT)+** — Nom 1 in. diam (or smaller) **Electrical Nonmetallic Tubing**. ENT installed in accordance with Article 331 of the National Electrical Code (NFPA No. 70).

See **Electrical Nonmetallic Tubing** (FKHU) category in the Electrical Construction Material Directory for names of manufacturers.

B. **Optical Fiber Raceways+** — Nom 1 in. diam (or smaller) **Optical Fiber Raceways**. Optical fiber raceway installed in accordance with Article 770 of the National Electrical Code (NFPA No.

70).

See **Optical Fiber Raceway** (QAZM) category in the Electrical Construction Material Directory for names of manufacturers.

3. **Firestop System** — The firestop system shall consist of the following:

A. **Packing Material** — Foam backer rod firmly packed into opening as a permanent form. Packing material to be recessed from both surfaces of wall as required to accommodate the required thickness of fill material.

B. **Fill, Void or Cavity Material\* - Caulk** — Min 1/2 in. thickness of fill material applied within the annulus, flush with both surfaces of wall. At point contact location, a min 3/8 in. diam bead of fill material shall be applied to the wall/penetrant interface on both surfaces of the wall.

**RECTORSEAL** — Metacaulk 1000

\*Bearing the UL Classification Mark