

## APPROVALS FOR METACAULK® PRODUCTS

Below is a list of Model Building Codes requiring the use of firestop products in various types of constructions and occupancies. Most local codes are derived from one or more of these model codes. Metacaulk® products and systems meet the through-penetration firestopping requirements of all of these codes.

ICC . . . . .	International Code Council; International Building Code
ICBO . . . . .	International Code of Building Officials; Uniform Building Code
SBCCI . . . . .	Southern Building Code Congress International; Standard Building Code
BOCA . . . . .	Building Official and Code Administrators International; National Building Code
CABO . . . . .	Council of American Building Officials (coordinating agency between ICBO, SBCCI and BOCA)
NBCC . . . . .	National Building Code of Canada
NFPA 101 . . . . .	National Fire Protection Association Life Safety Code
IRC . . . . .	International Residence Code

Certain cities, counties and states have written their own code requirements which may supersede or supplement model building codes, check with these authorities for approvals.

Metacaulk® Products are UL Classified and conform to the codes and test requirements shown below.

UL 1479 . . . . .	Fire Tests of Through-Penetration Firestops
UL 2079 . . . . .	Tests for Fire Resistance of Building Joint Systems
ASTM E 1966 . . . . .	Standard Test Method for Fire Resistive Joint Systems
ASTM E 814 . . . . .	Methods for Fire Tests of Through-Penetration Fire Stops
NFPA 101 . . . . .	National Fire Protection Association Life Safety Code
ASTM E 84 (UL 723) . . . . .	Test Method for Surface Burning Characteristics of Building Materials
ASTM E 119 (UL 263) . . . . .	Method for Fire Tests of Building Construction and Materials
ULC CAN4-S115M . . . . .	Standard Method of Fire Tests of Firestop Systems
ULC CAN/ULC-S101M . . . . .	Standard Methods of Fire Endurance Tests
B.S. 476/ pr EN 1366.3 . . . . .	European/ British Standards
AS 1530.4 . . . . .	Part 4: Fire Resistance Tests of Elements of Building Construction
AS 4072.1 . . . . .	Part 1: Service Penetration and Control Joint

For Questions or Additional Information call Technical Service 1-800-231-3345 • 1-713-263-8001  
 Fax 1-800-441-0051 • 1-713-263-7577