

Certificate of Compliance

Certificate Number **20090130-R14546F**
Report Reference **2009 January 30**
Issue Date **2009 January 30**

Page 1 of 2



**Underwriters
Laboratories Inc.**

Issued to: **Rectorseal**

2601 Spenwick Dr
Houston, TX 77055

*This is to certify that
representative samples of*

Gasketing and Edge Sealing Materials Fire Doors
Positive Pressure Tested (GVYI)


*Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized
licensee of UL in accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety:

ANSI/UL 10B, ANSI/UL 10C

Additional Information: See addendum for product listings

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product

Issued by:


Mona Couloute

Underwriters Laboratories Inc.

Reviewed by:


Matthew Schumann

Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number **20090130-R14546F**
Report Reference **2009 January 30**
Issue Date **2009 January 30**

Page 2 of 2



**Underwriters
Laboratories Inc.®**

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Perimeter Model Metacaulk Blaze Seal Category G Edge Sealing System for use with Category B wood and plastic covered composite doors rated up to 1-1/2 hr and Category B wood core doors rated 20 minute fire tested without hose streams. Also suitable as Category J Gaskets for use with Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs; and wood and plastic covered composite doors rated up to 1-1/2 hrs.

Issued by:

Mona Couloute
Mona Couloute

Underwriters Laboratories Inc.

Reviewed by:

Matthew Schumann
Matthew Schumann

Underwriters Laboratories Inc.